

**Table 1: Analytical Results**

<i>Sample No.</i>			<b>001</b>	<b>002</b>	<b>003</b>	<b>004</b>	<b>005</b>	<b>006</b>
<b>Parameter</b>	<b>Units</b>	<b>Primary Criteria *</b>						
<b>Arsenic (As)</b>	(µg/L)	10.0	0.59	0.82	84.6	0.76	11.8	184
<b>Mercury (Hg)</b>	(µg/L)	1	ND(0.3)	ND(0.3)	ND(0.3)	ND(0.3)	ND(0.3)	ND(0.3)
<b>Copper (Cu)</b>	(mg/L)	2.0	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)
<b>Zinc (Zn)</b>	(mg/L)	3.0	0.354	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)
<b>Nickel (Ni)</b>	(mg/L)	0.07	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)
<b>Lead (Pb)</b>	(mg/L)	0.01	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)
<b>Cadmium (Cd)</b>	(mg/L)	0.003	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)
<b>Cobalt (Co)</b>	(mg/L)	NC	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)
<b>Chromium (Cr)</b>	(mg/L)	0.05	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)	ND(0.02)
<b>Total Cyanide (CN)</b>	(mg/L)	0.07	ND(0.01)	ND(0.01)	ND(0.01)	ND(0.01)	ND(0.01)	ND(0.01)

**Abbreviations/Symbols**

\*

Based on World Health Organization (WHO) Drinking Water Quality Guidelines (2006)

--

Not analyzed.

NA

Not applicable.

NC

No criteria established.

ND (0.2)

Not detected at detection limit identified in parentheses.

3.7

Exceeds the established primary criteria