

Hydrogen-Sulfide Water Quality Testing Results

Sample ID	Water Source	Date	Time	Location	Additional Remarks	Day 1		Day 2		Day 3	
1	Control: Bottled Water	7/26/2007	06:55	Tavua	Hawaiian Fresh	NA	-	-	-	-	-
2	Nasivi River	7/26/2007	08:20	Upstream of pumping station		NA	-	+	+++	+++	+++
3	Tank - PWD Supplied	7/26/2007	10:40	Home E55		NA	-	-	+	+	+
4	Lololevu Creek	7/26/2007	12:15	Upstream of bridge (Lololevu I)		NA	-	++	+++	+++	+++
5	Tap Water	7/27/2007	12:30	Nasomo drinking water source		NA	-	+	+++	+++	+++
6	Tap Water	7/27/2007	3:15	Matanagata		NA	-	-	++	+++	+++
7	Boiled Tap Water	7/27/2007	3:25	Matanagata		NA	-	+	+++	+++	+++
8	Boiled Tap Water	7/27/2007	3:25	Matanagata		NA	-	++	+++	+++	+++
9	Tap Water	8/3/2007	10:15	Slime Dam	Kereni Marama's Tap	NA	-	+++	+++	+++	+++
10	Nasivi River	8/4/2007	12:30	Turtle Rocks swimming area		NA	-	+	++	+++	+++
<i>H2S Color Code</i>											
(-) No change											
(+) Slight change, the paper strip or water sample has turned grey											
(++) the paper strip or water sample is partially black											
(+++) the paper strip and the water sample are noticeably black											